

Portable Appliance Testing (PAT) Report / Certificate

Certificate Ref. # BNDT010520

Client: The Bandits (info@banditsmusic.co.uk)

Tested by: Bruce Asher

Equipment Used: Seaward PrimeTest 100

Address: The Frog and Wicket, Eversley Cross, Hampshire RG27 0NS

Test Date(s): 01/05/2020

Equipment Serial: 51K-0316

Asset #	Description	Serial #	Voltage (V)	Rating	Fuse (A)	Class	Earth Continuity (Ω)	Insulation Res. (M Ω)	Leakage (mA)	Polarity OK	Visual OK	Result
0001	Allen & Heath Qu-SB mixer	QUSBX-642150	240	45W		I	0.03	19.99	0.48		Y	PASS
0002	t.amp TSA 4-300 amplifier	(21)73331YAB00551	230	670W		I	0.02	19.99	1.07		Y	PASS
0003	TP-Link WiFi Router	2181B65002273	240	0.3A		II		19.99	0.1		Y	PASS
0005	t.racks Power 7 13A strip	(21)75300XGC00008	240	3680W		Cord	0.03	19.99		Y	Y	PASS
0008	IEC labelled "Mixer"		250		13	Cord	0.01	19.99		Y	Y	PASS
0009	IEC labelled "Amp"		250		13	Cord	0.01	19.99		Y	Y	PASS
0012	IEC to Powercon		250		13	Cord	0.01	19.99		Y	Y	PASS
0020	the box CL115 MkII sub	151203000586/	230	1000W	15	I	0.01	19.99	0.1		Y	PASS
0021	the box CL115 MkII sub	141206001323/	230	1000W	15	I	0.01	19.99	0.1		Y	PASS
0022	the box MA120 MkII monitor	(21)72475WGC00422	230	120W	12.5	I	0.01	19.99	0.1		Y	PASS
0025	Cameo flat LED parcan	MA25950517	240	15W	3	II		19.99	0.1		Y	PASS
0026	Cameo flat LED parcan	MA25930517	240	15W	3	II		19.99	0.1		Y	PASS
0027	Cameo flat LED parcan	MA25960517	240	15W	3	II		19.99	0.1		Y	PASS
0028	Cameo flat LED parcan	MA25940517	240	15W	3	II		19.99	0.1		Y	PASS
0032	IEC cable (speaker loom)		250		13	Cord	0.01	19.99		Y	Y	PASS
0033	IEC cable (speaker loom)		250		13	Cord	0.01	19.99		Y	Y	PASS
0058	Masterplug RCD adaptor	18W14	240	13A		Cord	0.01	19.99		Y	Y	PASS
0059	SMJ Cassette Reel 10m	CT1013	240	3120W		Cord	0.15	19.99		Y	Y	PASS
0060	4-gang Surge Extn.	SRGU42N 07C	240	3120W		Cord	0.03	19.99		Y	Y	PASS
0061	6-gang Surge Extn.		250	13A		Cord	0.07	19.99		Y	Y	PASS
0062	IEC cable		250		5	Cord	0.03	19.99		Y	Y	PASS
0063	IEC cable		250		5	Cord	0.04	19.99		Y	Y	PASS
0064	IEC cable		250		5	Cord	0.04	19.99		Y	Y	PASS
0065	IEC cable		250		5	Cord	0.04	19.99		Y	Y	PASS
0066	IEC cable		250		5	Cord	0.04	19.99		Y	Y	PASS
0067	IEC cable		250		5	Cord	0.04	19.99		Y	Y	PASS
0068	IEC cable		250		5	Cord	0.04	19.99		Y	Y	PASS
0069	IEC cable		250		5	Cord	0.03	19.99		Y	Y	PASS
0070	IEC cable		250		5	Cord	0.04	19.99		Y	Y	PASS
0071	IEC cable		250		5	Cord	0.04	19.99		Y	Y	PASS
0072	IEC cable		250		5	Cord	0.04	19.99		Y	Y	PASS
0073	16A to 4-gang extn.		240		13	Cord	0.07	19.99		Y	Y	PASS